




# AIR FACTORS

4771 ARROYO VISTA, SUITE D  
LIVERMORE, CA 94551


PH. # 925-579-0040  
FAX # 925-579-0044

## FLUSH FLANGE AIR BAR - FRAMING OPENING




AIR BAR	A Slot Width	B Framing Opening
B-10-FF	1	3-15/16
B-15-FF	1-1/2	4-15/16
B-20-FF	2	5-15/16
B-25-FF	2-1/2	7-9/16
B-30-FF	3	8-1/16

Drywall Opening = Slot Length +  $\frac{1}{2}$



### FLANGED END CAPS

Drywall Opening = Overall Length - D



AIR BAR	B-10-FF	B-15-FF	B-20-FF	B-25-FF	B-30-FF
C	1-7/8	2-3/8	2-7/8	3-1/2	4
D	1/4	1/4	1/4	1/4	1/4

### MITERED ENDS

9-54-A